



PRODUCT-DETAILS

E1.2C 1600 Ekip Touch LI 4p F F

E1.2C 1600 Ekip Touch LI 4p F F



	E1.2C 1600 Ekip Touch LI 4p F F
	1SDA071504R1
(EAN)	8015644753542
	E1.2C 1600 Ekip Touch LI 4p F F
	C.BREAKER SACE EMAX2 E1.2C 1600 FIXED FOUR-POLE WITH FRONT TERMINALS AND SOLID-STATE RELEASE IN AC EKIP/TOUCH-LI R 1600 FITTED WITH: 4 AUXILIARY CONTACT AND C.BREAKER IN POSITION OPEN-CLOSED

ABB EcoSolutions	
ABB EcoSolutions	
ABB	UL 2799 Zero Waste To Landfill Validation available
	9AKK108468A2360
- EPD	9AKK108468A1900 9AKK108468A3028
EN45555	Design for Closing Resource Loops - Standard EN45555 - 76.4 %

Material Compliance

REACH Declaration	9AKK108466A1425
RoHS	9AKK108466A1424
RoHS	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
Toxic Substances Control Act - TSCA	9AKK108467A8326

	9AKK108467A6707

USCON	ZACSEJBD000A000000XX
(EAN)	8015644753542
	1 piece
	85362090

	280 mm
	296 mm
	183 mm
	16 kg

1	box 1 piece
1	350 mm
1	350 mm
1	330 mm
1	18 kg
1 EAN	8015644753542

	SACE Emax 2
	Air Circuit Breaker
	Air Circuit Breaker
	F
CAD Dimensional Drawing	1SDH001252R0042

	AC
	Ue =< 440 V 3000 cycle
	Ue = 500 ... 690 V 6500 cycle
	30 cycles per hour
	20000 cycle
	60 cycles per hour
	100 %
(N)(I) ([%Iu])	

00	4P
0000	201 W
0000 (I _n)	1600 A
00000000 (U _{imp})	acc. to IEC 60947-2 12 kV
000000 (U _i)	AC 1000 V
000000	690 V AC
0000000000	(220 V AC) 50 kA
(I _{cs})	(230 V AC) 50 kA
	(380 V AC) 50 kA
	(400 V AC) 50 kA
	(415 V AC) 50 kA
	(440 V AC) 50 kA
	(500 V AC) 42 kA
	(660 V AC) 42 kA
	(690 V AC) 42 kA
0000000000	100 %
0000000000 (I _{cs})	
0000000 (I _{cw})	for 1 s 42 kA
	for 3 s 24 kA
0000000000	(400 V AC) 50 kA
(I _{cu})	(415 V AC) 50 kA
	(440 V AC) 50 kA
	(500 V AC) 42 kA
	(525 V AC) 42 kA
	(690 V AC) 42 kA
000000 (I _u)	1600 A
0000 (U _r)	690 V
000000	Main Circuit M10
000	Ekip Touch LI
00000	EL
000000	C
00	IEC
0000	E1.2
Suitable for IT Networks	Yes, 690V
000000	Front
0000	Bolt
0000	45 N·m

000000000000	
ATEX00	No certification needed
CSA 00	No certification needed
CSA 000000	No certification needed
0000000000	1SXF200023C2001
00000 - CE	9AKK106713A5546
UL00	No certification needed
VDE00	No certification needed
0000	1SDH000999R0101
000	1SDM000091R0001
000000	1SDH000999R0006
000000002000	1SDH001316R1002

00000000	
ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
IDEA 000000 (IGCC)	4926 >> Air circuit breakers
000000	Q
UNSPSC	39121615

WEEE 	5. Small Equipment (No External Dimension More Than 50 cm)
	V11.1 : 27370409



 →  →  → Emax 2

